

**MODIFICATION TO TUCSON WATER STANDARD WATERWORKS SPECIFICATION  
NO. 0210, PIPE MARKING, DETECTION TAPE AND TRACER WIRE**

**0210.0301 General**

**REMOVE THE ENTIRE SECTION (A):**

**(B) Potable Water Detectable Pipe Locating Tape**

**REMOVE PARAGRAPH ONE AND REPLACE WITH THE  
FOLLOWING:**

Following installation of pipe bedding and backfill to 24-inches above the top of pipe in accordance with MDWID specifications, the Contractor is required to install polyethylene potable water detectable pipe locating tape. The backfill shall be sufficiently leveled to provide a flat surface for installation of the tape. The tape shall be centered in the trench and laid flat with printed side up in accordance with MDWID Standard Detail MW-115, page 2 of 2. Caution shall be exercised during completion of backfill to avoid displacement of or damage to warning tape.

**CHANGE SECTION (C), RECLAIMED WATER DETECTABLE PIPE  
LOCATING TAPE, PARAGRAPH 2 AS FOLLOWS:**

“CAUTION NON-POTABLE WATERLINE: CONTACT METRO WATER”

**(B) Tracer Wire**

**REMOVE PARAGRAPH ONE AND REPLACE WITH THE  
FOLLOWING:**

Tracer wire shall be installed in accordance with Tucson Water SD-116 and MDWID SD-115.