

**MODIFICATION TO TUCSON WATER STANDARD WATERWORKS SPECIFICATION
NO. 1404, POLYVINYL CHLORIDE PIPE**

1404.0201 Materials.

(B) Pressure Class.

REMOVE THIS SECTION AND REPLACE WITH THE FOLLOWING:

Unless otherwise specified on the plans or in the special specifications, PVC pipe shall be pressure class 200, dimension ratio 14 (DR 14) (cast iron O.D.). MDWID authorization is required for use of 12” or larger PVC pipe.