

**MODIFICATION TO TUCSON WATER STANDARD WATERWORKS SPECIFICATION
NO. 1426, VALVE BOX AND COVER**

1426.0103 Submittals.

REMOVE AND REPLACE WITH THE FOLLOWING:

Valve Boxes shall appear on the MDWID Approved Materials List.

1426.0201 Materials.

(A) Valve Boxes and Covers

REMOVE PARAGRAPH AND REPLACE WITH THE FOLLOWING:

Valve boxes shall be one piece with inside fitting cover. Valve boxes and covers shall be heavy cast iron in conformance with ASTM A48, Class 30 B. Covers shall be marked "METRO WATER VALVE". Valve boxes shall be equipped with lugs or lips for setting in concrete. Valve boxes and covers shall conform to the requirements of Standard Detail No. MW-300.

1426.0302 Existing Valve Box and Cover Adjustments

REMOVE THIS ENTIRE SECTION: