

**MODIFICATION TO TUCSON WATER STANDARD WATERWORKS SPECIFICATION
NO. 1433, RECLAIMED WATERLINES**

1433.0301 General.

(A) Utility Separation.

REMOVE THIS SECTION AND ADD THE FOLLOWING:

Reclaimed waterlines will be treated as sewer when crossing or running adjacent to potable waterlines.

Reclaimed waterlines will be treated as potable when crossing or running adjacent to sewer lines. (SD 106).

(E) High Density Polyethylene Pipe.

REMOVE THIS SECTION:

(H) Installation of Water Meters, Meter Boxes, and Service Lines.

**REMOVE PARAGRAPH ONE (1) AND REPLACE WITH THE
FOLLOWING:**

Water Meter for use of Reclaimed Waterlines will be installed by Metro Water District staff only or as directed by the District Engineer.