

**MODIFICATION TO TUCSON WATER STANDARD WATERWORKS SPECIFICATION
NO. 1405, GALVANIZED STEEL PIPE**

1405.0301 General.

ADD THE FOLLOWING BEFORE PARAGRAPH ONE:

Galvanized steel pipe shall not be used where the pipe will be subject to continuous contact with water.