

**MODIFICATION TO TUCSON WATER STANDARD WATERWORKS SPECIFICATION
NO. 1410, RESILIENT-SEATED GATE VALVE**

1410.0201 Materials.

(A) Standard.

**REMOVE PARAGRAPH ONE AND REPLACE WITH THE
FOLLOWING:**

Resilient-seated gate valves and the materials used in their manufacture shall comply with the Standard in Appendix B and appear on the MDWID Approved Materials List.

(C) Component Parts.

CHANGE ITEM NUMBER (6) AS FOLLOWS:

- (6) All exterior ferrous surfaces except fasteners shall be factory coated with a fusion bonded epoxy in accordance with AWWA C550 and shall be suitable for contact with potable water. Nuts and bolts shall be ASTM type 304 stainless steel. Nuts or bolts shall be factory coated with anti-seize material.