

**MODIFICATION TO TUCSON WATER STANDARD WATERWORKS SPECIFICATION
NO. 1425, VALVE NUT EXTENSION**

1425.0104 Delivery, Storage and Handling.

REMOVE THIS SECTION AND REPLACE WITH THE FOLLOWING:

Valve nut extensions shall be provided by the Contractor. Valve nut extensions shall be delivered to the site, stored, and handled so as to avoid damage or deformation.

1425.0301 Installation.

REMOVE THIS SECTION AND REPLACE WITH THE FOLLOWING:

- (A) **Valve Extension stems.** Valve extension stems shall be installed in accordance with Tucson Water Standard Detail No. 305, except modified by MDWID Standard Detail MW-305. Valve nut extensions shall not be permanently attached to the valve nut.