

BACKFLOW PREVENTION

NOTES:

1. THIS DETAIL SUPPLEMENTS TUCSON WATER STANDARD DETAILS SD-1800 – SD-1810.
2. ALL DETAILS, SEE MDWID SUPPLEMENTAL SPECIFICATION FOR BACKFLOW PREVENTION FOR INSTALLATION AND MATERIAL REQUIREMENTS.
3. ALL DETAILS, FOR ADDITIONAL INFORMATION CONTACT THE MDWID BACKFLOW PREVENTION INSPECTOR AT (520) 575-8100.
4. ALL DETAILS, INSTALLATIONS SHALL MEET CURRENT INTERNATIONAL PLUMBING CODES IN ADDITION TO TUCSON WATER STANDARD DETAILS.
5. SD-1801, ANY WATER TRUCKS OR TANKS THAT ARE FILLED FROM A POTABLE WATER SUPPLY SUCH AS A FIRE HYDRANT OR WATER HOSE SHALL BE FITTED WITH A REDUCED PRESSURE BACKFLOW ASSEMBLY OR BE FILLED THROUGH AN AIR GAP, WITH NO WAY TO BYPASS.
6. SD-1801, ALL HOSES USED TO FILL TANKS SHALL NOT HAVE BEEN USED TO CONVEY ANY SUBSTANCE OTHER THAN POTABLE WATER.
7. SD-1801, BACKFLOW PREVENTION FOR MOBILE UNITS SHALL BE INSPECTED AND APPROVED BY MDWID PRIOR TO USE.
8. SD-1801, HYDRANT MOUNTED RP BACKFLOW ASSEMBLY SHALL BE FURNISHED AND MAINTAINED BY THE CONTRACTOR, AND SHALL BE TESTED IN ACCORDANCE WITH MDWID SPECIFICATIONS AND ALL APPLICABLE CODES.



BACKFLOW PREVENTION NOTES

ISSUED: 01/99
REVISED: 07/2014

SCALE: N.I.S.

PAGE 1 OF 1

S.D.# MW-1800