

MODIFICATION TO TUCSON WATER STANDARD WATERWORKS SPECIFICATION NO. 1411, BUTTERFLY VALVE

1411.0103 Contractor Submittals.

ADD THE FOLLOWING TO THE END OF THE 2ND SENTANCE IN ITEM FOUR:

...adequate to train service personnel in repair prior to filling orders.

ADD THE FOLLOWING AS SECTION NINE:

An “Affidavit of Compliance” is required from the manufacturer stating that the valves furnished comply with these specifications.

1411.0201 Materials.

(A) Standards.

REMOVE PARAGRAPH ONE AND REPLACE WITH THE FOLLOWING:

Butterfly valves and the materials used in their manufacture shall comply with the Standards in Appendix B and appear on the MDWID Approved Materials List.

1411.0301 General.

ADD THE FOLLOWING TO PART A:

Nuts or bolts shall be factory coated with anti-seize material.