



# Metro Water District Hub Service Area Consumer Confidence Report for Calendar Year 2022

Este informe contiene información muy importante sobre el agua usted bebe.  
Tradúscalo ó hable con alaiuen que lo entienda bien.

Public Water System ID Number	Public Water System Name		
AZ04-10-060	METROPOLITAN DWID – HUB		
Contact Name and Title	Phone Number	E-mail Address	
Steve Shepard, Utility Superintendent	(520) 575-8100	sshepard@metrowater.com	
<p>We want our valued customers to be informed about their water quality. If you would like to attend any of our regularly scheduled meetings, please visit <a href="https://metrowater.com/public-meetings">https://metrowater.com/public-meetings</a>. Metro Water District's Board of Directors meets regularly, usually on the second Monday of the month, at 6:00 p.m. at Metro Water District's Office located at 6265 N. La Cañada Drive, Tucson, Arizona 85704.</p>			

### Drinking Water Sources

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. The District's water is from the Tucson Basin. The water in our aquifer was created primarily from mountain runoff and storm water infiltrating beneath the ground. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, and in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, the Environmental Protection Agency (EPA) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

<b>Our water source(s):</b>	Groundwater (Wells)
-----------------------------	---------------------

### Consecutive Connection Sources

A public water system that receives some or all of its finished water from one or more wholesale systems by means of a direct connection or through the distribution system of one or more consecutive systems. Systems that purchase water from another system report regulated contaminants detected from the source water supply in a separate table.

**PWS # AZ04-10-112, City of Tucson provides us a consecutive connection source of water. The City of Tucson's 2021 CCR Report may be viewed at <https://www.tucsonaz.gov/water>.**

### Drinking Water Contaminants

**Microbial Contaminants:** Such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

**Inorganic Contaminants:** Such as salts and metals that can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

**Pesticides and Herbicides:** Such as agriculture, urban storm water runoff, and residential uses that may come from a variety of sources.

**Organic Chemical Contaminants:** Such as synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.

**Radioactive Contaminants:** That can be naturally occurring or be the result of oil and gas production and mining activities.

## Vulnerable Population

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

## Source Water Assessment

The Arizona Department of Environmental Quality (ADEQ) completed a source water assessment for the drinking water in the Metro Hub Service Area in February 2003. Based on the information currently available on the hydrogeologic settings and the adjacent land uses that are in the specified proximity of the drinking water source(s) of this public water system, the department has given a low-risk designation for the degree to which this public water system drinking water source(s) are protected. A low-risk designation indicates that most source water protection measures are either already implemented, or the hydrogeology is such that the source water protection measures will have little impact on protection. Further source water assessment documentation can be obtained by contacting ADEQ.

## Definitions

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water

**Level 1 Assessment:** A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria was present

**Level 2 Assessment:** A very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria was present

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment, or other requirements

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health

**Maximum Residual Disinfectant Level (MRDL):** The level of disinfectant added for water treatment that may not be exceeded at the consumer's tap

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of disinfectant added for treatment at which no known or anticipated adverse effect on health of persons would occur

**Minimum Reporting Limit (MRL):** The smallest measured concentration of a substance that can be reliably measured by a given analytical method

**Millirems per year (MREM):** A measure of radiation absorbed by the body

**Not Applicable (NA):** Sampling was not completed by regulation or was not required

**Not Detected (ND or <):** Not detectable at reporting limit

**Nephelometric Turbidity Units (NTU):** A measure of water clarity

**Million fibers per liter (MFL)**

**Picocuries per liter (pCi/L):** Measure of the radioactivity in water

**ppm:** Parts per million or Milligrams per liter (mg/L)

**ppb:** Parts per billion or Micrograms per liter (µg/L)

**ppt:** Parts per trillion or Nanograms per liter (ng/L)

ppm x 1000 = ppb

**ppq:** Parts per quadrillion or Picograms per liter (pg/L)

ppb x 1000 = ppt

ppt x 1000 = ppq

## Lead Informational Statement:

Lead, in drinking water, is primarily from materials and components associated with service lines and home plumbing. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Metro Water District is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

## Water Quality Data – Regulated Contaminants

Microbiological (RTCR)	TT Violation Y or N	Number of Positive Samples	Positive Sample(s) Month & Year	MCL	MCLG	Likely Source of Contamination	
E. Coli	N	0	NA	0	0	Human and animal fecal waste	
Fecal Indicator (coliphage, enterococci and/or E. coli)	N	0	NA	0	0	Human and animal fecal waste	
Disinfectants	MCL Violation Y or N	Running Annual Average (RAA)	Range of All Samples (Low-High)	MRDL	MRDLG	Sample Month & Year	Likely Source of Contamination
Chlorine/Chloramine (ppm)	N	0.6	0.5 to 0.9	4	4	2022	Water additive used to control microbes
Disinfection By-Products	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Haloacetic Acids (HAA5) (ppb)	N	<2.0	<2.0	60	N/A	2022	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHM) (ppb)	N	9.5	9.5	80	N/A	2022	Byproduct of drinking water disinfection
Lead & Copper	MCL Violation Y or N	90 <sup>th</sup> Percentile	Number of Samples Exceeds AL	AL	ALG	Sample Month & Year	Likely Source of Contamination
Copper (ppm)	N	.004	0	1.3	1.3	2022	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	N	1.9	0	15	0	2022	Corrosion of household plumbing systems; erosion of natural deposits
Radionuclides	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Alpha Emitters (pCi/L)	N	1.5	1.5	15	0	2022	Erosion of natural deposits
Combined Radium-226 & -228 (pCi/L)	N	<0.6	<0.6	5	0	2022	Erosion of natural deposits
Inorganic Chemicals (IOC)	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Antimony (ppb)	N	<0.5	<0.5	6	6	2022	Discharge from petroleum refineries; fire retardants; ceramics, electronics, and solder
Arsenic <sup>1</sup> (ppb)	N	7.6	1.2 to 7.6	10	0	2022	Erosion of natural deposits, runoff from orchards, runoff from glass and electronics production wastes
Barium (ppb)	N	45	2.0 to 45	2000	2000	2022	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits
Beryllium (ppb)	N	<1.0	<1.0	4	4	2022	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	N	<0.5	<0.5	5	5	2022	Corrosion of galvanized pipes; natural deposits; metal refineries; runoff from waste batteries and paints
Chromium (ppb)	N	<1.0	<1.0	100	100	2022	Discharge from steel and pulp mills; Erosion of natural deposits
Cyanide (ppb)	N	<25	<25	200	200	2022	Discharge from steel/metal factories; Discharge from plastic and fertilizer factories
Fluoride (ppm)	N	1.40	0.51 to 1.40	4	4	2019	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

Inorganic Chemicals (IOC) Cont.	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Mercury (ppb)	N	0.14	<0.20 to 0.14	2	2	2019	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills and cropland.
Nitrate <sup>2</sup> (ppm)	N	2.10	0.61 to 2.10	10	10	2021	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite (ppm)	N	<0.05	<0.05	1	1	2019	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium (ppb)	N	<5.0	<5.0	50	50	2019	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium (ppm)	N	33	24 to 33	N/A	N/A	2021	Erosion of natural deposits
Thallium (ppb)	N	<1.0	<1.0	2	0.5	2019	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories

<sup>1</sup> **Arsenic** is a mineral known to cause cancer in humans at high concentration and is linked to other health effects, such as skin damage and circulatory problems. If arsenic is less than or equal to the MCL, your drinking water meets EPA's standards. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water and continues to research the health effects of low levels of arsenic.

<sup>2</sup> **Nitrate** in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause "blue baby syndrome." Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, and detected nitrate levels are above 5 ppm, you should ask advice from your health care provider.

Synthetic Organic Chemicals (SOC)	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Alachlor (ppb)	N	<0.1	<0.1	2	0	2022	Runoff from herbicide used on row crops
Chlordane (ppb)	N	<0.1	<0.1	2	0	2022	Residue of banned termiticide
Dibromochloropropane (ppt)	N	<0.01	<0.01	200	0	2022	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards
Endrin (ppb)	N	<0.01	<0.01	2	2	2022	Residue of banned insecticide
Ethylene dibromide (ppt)	N	<0.01	<0.01	50	0	2022	Discharge from petroleum refineries
Heptachlor (ppt)	N	<0.01	<0.01	400	0	2022	Residue of banned termiticide
Heptachlor epoxide (ppt)	N	<0.01	<0.01	200	0	2022	Breakdown of heptachlor
Lindane (ppt)	N	<0.01	<0.01	200	200	2022	Runoff/leaching from insecticide used on cattle, lumber, gardens
Methoxychlor (ppb)	N	<0.05	<0.05	40	40	2022	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa,
PCBs [Polychlorinated biphenyls] (ppt)	N	<0.1	<0.1	500	0	2022	Runoff from landfills; discharge of waste chemicals
Toxaphene (ppb)	N	<0.5	<0.5	3	0	2022	Runoff/leaching from insecticide used on cotton and cattle
Volatile Organic Chemicals (VOC)	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Benzene (ppb)	N	<0.5	<0.5	5	0	2022	Discharge from factories; leaching from gas storage tanks and landfills
Carbon tetrachloride (ppb)	N	<0.5	<0.5	5	0	2022	Discharge from chemical plants and other industrial activities
Chlorobenzene (ppb)	N	<0.5	<0.5	100	100	2022	Discharge from chemical and agricultural chemical factories
o-Dichlorobenzene (ppb)	N	<0.5	<0.5	600	600	2022	Discharge from industrial chemical factories

Volatile Organic Chemicals (VOC) Cont.	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
p-Dichlorobenzene (ppb)	N	<0.5	<0.5	75	75	2022	Discharge from industrial chemical factories
1,2-Dichloroethane (ppb)	N	<0.5	<0.5	5	0	2022	Discharge from industrial chemical factories
1,1-Dichloroethylene (ppb)	N	<0.5	<0.5	7	7	2022	Discharge from industrial chemical factories
cis-1,2-Dichloroethylene (ppb)	N	<0.5	<0.5	70	70	2022	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	N	<0.5	<0.5	100	100	2022	Discharge from industrial chemical factories
Dichloromethane (ppb)	N	<0.5	<0.5	5	0	2022	Discharge from pharmaceutical and chemical factories
1,2-Dichloropropane (ppb)	N	<0.5	<0.5	5	0	2022	Discharge from industrial chemical factories
Ethylbenzene (ppb)	N	<0.5	<0.5	700	700	2022	Discharge from petroleum refineries
Styrene (ppb)	N	<0.5	<0.5	100	100	2022	Discharge from rubber and plastic factories; leaching from landfills
Tetrachloroethylene (ppb)	N	<0.5	<0.5	5	0	2022	Discharge from factories and dry cleaners
1,2,4-Trichlorobenzene (ppb)	N	<0.5	<0.5	70	70	2022	Discharge from textile-finishing factories
1,1,1-Trichloroethane (ppb)	N	<0.5	<0.5	200	200	2022	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	N	<0.5	<0.5	5	3	2022	Discharge from industrial chemical factories
Trichloroethylene (ppb)	N	<0.5	<0.5	5	0	2022	Discharge from metal degreasing sites and other factories
Toluene (ppm)	N	<0.5	<0.5	1	1	2022	Discharge from petroleum factories
Vinyl Chloride (ppb)	N	<0.3	<0.3	2	0	2022	Leaching from PVC piping; discharge from chemical factories
Xylenes (ppm)	N	<0.5	<0.5	10	10	2022	Discharge from petroleum or chemical factories

#### Water Quality Table – Elective Samples from 2022

Metals	Detected (Y/N)	Average	Range of All Samples (Low-High)	MRL	Likely Source of Contamination
Manganese (ppb)	Y	1.9	0.3 to 7.8	0.4	Naturally occurring element; commercially available in combination with other elements and minerals; used in steel production, fertilizer, batteries, and fireworks; drinking water and wastewater treatment chemical; essential nutrient
PFAS	Detected (Y/N)	Average	Range of All Samples (Low-High)	MRL	Likely Source of Contamination
Hexafluoropropylene Oxide Dimer Acid (HFPO-DA/GenX) (ppb)	Y	<0.0020	<0.0020	0.002	Emulsifier or surfactant used to make coatings, cleaners, paint and other textiles.
N-ethylperfluorooctanesulfonamidoacetic acid (NEtFOSAA) (ppb)	Y	<0.0020	<0.0020	0.002	Emulsifier or surfactant used to make coatings, cleaners, paint and other textiles.
N-methylperfluorooctanesulfonamidoacetic Acid (N-MeFOSAA) (ppb)	Y	<0.0020	<0.0020	0.002	Emulsifier or surfactant used to make coatings, cleaners, paint and other textiles.
Perfluorobutanesulfonic Acid (PFBS) (ppb)	Y	0.0011	0.00059 to 0.0016	0.002	Synthetic chemical used in products to make them stain, grease, heat and water resistant.
Perfluorodecanoic Acid (PFDA) (ppb)	Y	<0.0020	<0.0020	0.002	Synthetic chemical used in products to make them stain, grease, heat and water resistant.
Perfluorododecanoic Acid (PFdDA) (ppb)	Y	<0.0020	<0.0020	0.002	Synthetic chemical used in products to make them stain, grease, heat and water resistant.
Perfluorohexanesulfonic Acid (PFHxS) (ppb)	Y	0.0007	0.0005 to 0.0009	0.002	Synthetic chemical used in products to make them stain, grease, heat and water resistant.
Perfluorohexanoic Acid (PFHA) (ppb)	Y	0.0013	0.0028 to 0.0059	0.002	Emulsifier or surfactant used to make coatings, cleaners, paint and other textiles.
Perfluorooctanesulfonic Acid (PFOS) (ppb)	Y	0.0006	0.0004 to 0.0009	0.002	Synthetic chemical used in products to make them stain, grease, heat and water resistant.
Perfluorooctanoic Acid (PFOA) (ppb)	Y	0.00086	0.00012 to 0.00086	0.002	Emulsifier or surfactant used to make coatings, cleaners, paint and other textiles.
Perfluorotridecanoic Acid (PFtDA) (ppb)	Y	<0.0020	<0.0020	0.002	Emulsifier or surfactant used to make coatings, cleaners, paint and other textiles.

**Violation Summary (for Reporting Requirement)**

<b>Violation Type</b>	<b>Explanation, Health Effects</b>	<b>Time Period</b>	<b>Corrective Actions</b>
Reporting Violation	Late Reporting of the Third Quarter 2022 Monitoring Residual Disinfection Levels (MRDLs) to ADEQ within the ten-day time period allotted after the end of the quarter. The samples were collected on-time, but the report was turned in late. There were no water quality impacts, the violation was a paperwork process issue.	Reported on November 21, 2022.	There were no adverse health effects due to this late reporting for the MRDLs, and the System did not serve any contaminated water. The MRDLs were sent in as soon as the error was noticed. The ADEQ returned the System to compliance on November 21, 2022.
Please share this information with other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.			