



2025 WATER QUALITY REPORT

METRO SOUTHWEST DIABLO VILLAGE SERVICE AREA

METRO WATER DISTRICT DELIVERS SAFE, RELIABLE DRINKING WATER

Office Location

6265 N. La Cañada Dr.
Tucson, Arizona 85704

Customer Service

7:30 a.m. – 4:30 p.m.
Monday – Thursday
7:30 a.m. – noon
Friday

Contact us at

520-575-8100
info@metrowater.com

Visit us at

www.metrowater.com

Board of Directors

Scott Schladweiler, Chair
Richard Sarti, Vice Chair
Jim Doyle, Member
Bryan Foulk, Member
Lee Jacobs, Member

Board Meetings

are held at 6265 N. La Cañada Drive the second Monday of each month at 6:00 p.m. If Monday falls on a holiday, the meeting is moved to Wednesday.

To request a printed copy of this report, please call us at (520)575-8100

or email us at info@metrowater.com

Este informe contiene información sobre el agua que consume. Si necesita obtener más información, comuníquese con nosotros al 1-520-575-8100.



Metro Water District (District) is pleased to report that the water delivered to your faucet meets all safe drinking water standards. This annual Water Quality Report is required by the Federal Government under the Safe Drinking Water Act. We believe customers who are well informed about their water supply are our best allies in supporting improvements necessary to maintain safe and reliable water.

WHERE DOES YOUR WATER COME FROM?

The District uses groundwater from the southwest portion of the Tucson Basin aquifer. The water in our aquifer was created primarily from mountain runoff and storm water infiltrating into the ground along the Brawley Wash.

The Diablo Village service area is located in the vicinity of Ajo Highway and Valencia Road near Ryan Airfield. Diablo Village has two active wells that pump water from the local aquifer. Depth to water ranges from 367.96 to 427.94 feet. Water from wells is pumped into storage tanks and then moved underground through pipes to reach your home by pressure.

While water is made up of hydrogen and oxygen, this life-giving liquid also contains many naturally occurring minerals that affect the taste and hardness of your water. Unfortunately, human-caused and naturally occurring contaminants can also be found in water. This is why the Safe Drinking Water Act exists.

HOW DO YOU KNOW YOUR WATER IS SAFE?

The District routinely checks its water for contaminants. In 2025, 181 samples were collected to meet Federal and State regulations, as well as to test for constituents that may or may not be regulated in the near future.

HOW IS YOUR WATER TESTED?

Trained staff collects samples from wells, storage facilities, points in the distribution system, and residents' homes. The samples are analyzed by State licensed laboratories. The test results are reported to the District and the State of Arizona. The District works closely with the Arizona Department of Environmental Quality (ADEQ) to ensure all water quality standards are met.

WHAT HAPPENS IF THE WATER TESTED INDICATES CONTAMINATION?

If the public water supply is found not to meet the safe drinking water standards, the District is required by Federal and State regulations to notify customers within affected service areas. Notification may be made by mail and/or through the news media. If a serious situation occurs that may affect the health and well-being of our customers, the District would do whatever is necessary to notify you and provide an alternate source of safe drinking water.

WHAT CONTAMINANTS MIGHT BE DETECTED?

The table on page 3 shows the detected results. The levels of detected contaminants meet the Safe Drinking Water Act standards.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. Environmental Protection Agency's (EPA) Safe Drinking Water Hotline at 1-800-426-4791. You can also visit the EPA's website regarding the Safe Drinking Water Act at <https://www.epa.gov/sdwa>

The source of our drinking water is from wells. As water travels through the ground, naturally-occurring

minerals, and in some cases radioactive material, are dissolved. Water can also pick up dissolved substances resulting from the presence of plants, animals or from human activity.

Contaminants that may be present in the public water supply include microbial such as viruses and bacteria; inorganics such as salts and metals; pesticides and herbicides; organic chemical contaminants, both synthetic and volatile; and radioactive contaminants.

WHERE DO CONTAMINANTS COME FROM?

Contaminants can be man-made or naturally-occurring. **Microbial contaminants** may come from sewage treatment plants, septic systems, residential uses, agricultural activity, livestock operations, and wildlife.

Inorganic contaminants can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharge, oil and gas production, mining or farming.

Pesticides and herbicides may come from many sources, such as agriculture, urban runoff, and residential use.

Radioactive contaminants can be naturally-occurring or be the result of oil and gas production and mining activities.

Organic chemical contaminants are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

IS YOUR WATER TREATED?

The District adds chlorine to its water to eliminate any type of bacterial contamination that could occur in the water pipes. If you notice a persistent chlorine taste or odor, please contact the District. ♦

ELECTIVE MONITORING FOR UNREGULATED CONSTITUENTS IN 2025

The District collects elective samples in order to ensure the delivery of safe, reliable water to its Customers. While elective samples are not required for compliance, they assist the District in evaluating water quality to ensure compliance with future drinking water standards.

Water Quality Parameter	Water Maximum Level Detected	Water Range of Detections	EPA* Maximum Contaminant Level (MCL)	EPA* Maximum Contaminant Level Goal (MCLG)	Units	Potential Sources of Contaminant	Sample Year ***
Hexavalent Chromium	<0.10	<0.10	NA	NA	ppb	Naturally occurring element; used in steel alloys; used for plating, dyes, and wood preservation.	Not detected in 2025

METRO SOUTHWEST – DIABLO VILLAGE DETECTED REGULATED CONTAMINANTS IN 2025

Water Quality Parameter	Maximum Level Detected	Range of Detections	EPA* Maximum Contaminant Level (MCL)	EPA* Maximum Contaminant Level Goal (MCLG)	Units	Potential Sources of Contaminant	Sample Date ***
Microbiological Monitoring							
E. Coli	0	0	One positive monthly sample	Not Present	0	Naturally present in the environment.	2025
Radiochemical Monitoring							
Gross Alpha	10.0	10.0	15	0	pCi/L	Erosion and natural deposits.	2025
Combined Radium (Radium 226& 228)	0.417	0.417	5	0	pCi/L	Erosion and natural deposits.	2025
Inorganic & Metals Monitoring							
Aluminum	5.2	2 to 5.2	NA	NA	ppb	Erosion of natural deposits.	2025
Arsenic	1.70	0.14 to 1.70	10	0	ppb	Erosion of natural deposits; runoff from agriculture.	2025
Barium	0.23	0.21 to 0.23	2	2	ppm	Erosion of natural deposits; discharge from drilling muds; leaching from bricks and tiles containing barium.	2025
Fluoride†	2.80	0.59 to 2.80	4	4	ppm	Erosion of natural deposits; discharge from fertilizer production.	2025
Sodium	60	59 to 60	NA	NA	ppm	Erosion of natural deposits.	2025
Disinfection By-Product Monitoring							
Chlorine Residual	0.65	0.4 to 0.65	4.0 **	4.0 **	ppm	By-product of drinking water chlorination.	2025
Nitrate							
Nitrate (as Nitrogen)	1.6	1.6	10	10	ppm	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits.	2025

Water Quality Parameter	90th Percentile Level and No. of Samples Over the Action Level	Range of Samples	EPA* Contaminant Action Level (AL)	EPA* Maximum Contaminant Level Goal (MCGL)	Units	Potential Sources of Contaminant	Sample Date ***
Copper & Lead Monitoring							
Copper	0.376 No samples were above the Action Level.	0.006 to 0.092	1.3	1.3	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.	2024
Lead	0.432 No samples were above the Action Level.	<0.50 to 0.54	15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits.	2024

* EPA is the acronym for the U.S. Environmental Protection Agency

** The MCL and MCLG for Chlorine Residual is actually the Maximum Residual Disinfection Level (MRDL)

*** The data presented in the report are from the most recent testing done in accordance with drinking water regulations

† See Page 5 for additional information on Fluoride

TUCSON WATER DETECTED REGULATED CONTAMINANTS IN 2025

Microbiological (RTCR)	TT Violation Y or N	Number of Positive Samples	Positive Sample(s) Month & Year	MCL	MCLG	Likely Source of Contamination	
E. Coli	N	1	8/2025	0	0	Human and animal fecal waste	
Disinfectants	MCL Violation Y or N	Running Annual Average (RAA)	Range of All Samples (Low-High)	MRDL	MRDLG	Sample Month & Year	Likely Source of Contamination
Chlorine (ppm)	N	1.00	0.94 – 1.07	4	4	2025	Water additive used to control microbes
Disinfection By-Products	MCL Violation Y or N	Running Annual Average (RAA)	Range of All Samples (Low-High)	MCL	MCLG	Sample Year	Likely Source of Contamination
Haloacetic Acids (HAA5) (ppb)	N	1.3	ND – 2.1	60	N/A	2025	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHM) (ppb)	N	13.6	1.8 – 26.8	80	N/A	2025	Byproduct of drinking water disinfection
Lead & Copper	MCL Violation Y or N	90th Percentile	Number of Samples Exceeds AL	AL	ALG	Sample Year	Likely Source of Contamination
Copper (ppm)	N	0.135	0	1.3	1.3	2023	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	N	0.65	0	15	0	2023	Corrosion of household plumbing systems; erosion of natural deposits
Radionuclides	MCL Violation Y or N	Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Year	Likely Source of Contamination
Alpha Emitters (pCi/L)	N	4.4	ND – 4.4	15	0	2025	Erosion of natural deposits
Combined Radium -226 & -228 (pCi/L)	N	1.44	ND – 1.44	5	0	2025	Erosion of natural deposits
Uranium (ug/L)	N	16	ND -- 16	30	0	2025	Erosion of natural deposits
Inorganic Chemicals (IOC)	MCL Violation Y or N	Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Year	Likely Source of Contamination
Arsenic ¹ (ppb)	N	8.8	ND – 8.8	10	0	2025	Erosion of natural deposits, runoff from orchards, runoff from glass and electronics production wastes
Barium (ppm)	N	0.15	ND – 0.15	2	2	2025	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Fluoride (ppm)	N	0.80	0.13 – 0.80	4	4	2025	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate ² (ppm)	N	6.7	0.25 – 6.7	10	10	2025	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium (ppb)	N	4.3	ND – 4.3	50	50	2025	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium (ppm)	N	70.4	22.4 – 70.4	N/A	N/A	2025	Erosion of natural deposits
<p>¹ Arsenic is a mineral known to cause cancer in humans at high concentration and is linked to other health effects, such as skin damage and circulatory problems. If arsenic is less than or equal to the MCL, your drinking water meets EPA's standards. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water and continuing to research the health effects of low levels of arsenic.</p> <p>² Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause "blue baby syndrome." Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, and detected nitrate levels are above 5 ppm, you should ask advice from your health care provider.</p>							
Synthetic Organic Chemicals (SOC)	MCL Violation Y or N	Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Year	Likely Source of Contamination
Atrazine (ppb)	N	0.09	ND – 0.09	3	3	2025	Runoff from herbicide used on row crops
Simazine (ppb)	N	0.05	ND – 0.05	4	4	2025	Herbicide runoff

TUCSON WATER DETECTED UNREGULATED CONTAMINANTS IN 2025

One Metal	Detected Y or N	Average	Range of All Samples (Low-High)	MRL (ppb)	Analytical Methods
Lithium (ppb)	Y	14.8	ND – 63.7	9 ppb	EPA 200.7

The District takes extra measures to ensure the delivery of safe, reliable water, such as auxiliary pumping units, generators, and emergency interconnects from neighboring water utilities. The use of the emergency interconnects are infrequent; however, does occur in short durations. Although you may have received only a small amount of water from the interconnect, the District wants to ensure our customers are fully informed about water quality. Tucson Water's 2025 Consumer Confidence Report is available at <https://www.tucsonaz.gov/Departments/Water/Water-Quality/> ♦

ARSENIC:

Arsenic is known to cause cancer in humans. Arsenic also may cause other health effects such as skin damage and circulatory problems. The District meets the EPA arsenic drinking water standard, also known as a Maximum Contaminant Level (MCL). However, you should know that EPA's MCL for arsenic balances the scientific community's understanding of arsenic-related health effects and the cost of removing arsenic from drinking water.

The District maintains an arsenic treatment system at Diablo Village Well No. 1 to ensure compliance for arsenic below the standard of 10 ppb. The compliance testing in 2025 after the treatment system showed the highest level of arsenic to be 1.7 ppb, which is less than the EPA's MCL of 10 ppb.

ELEVATED FLUORIDE LEVELS DETECTED†:

The District is required to test every three years for fluoride. In 2025, the highest detected fluoride was 2.8 mg/l. Drinking water containing more than 4 mg/l of fluoride (the U.S. Environmental Protection Agency's drinking water standard) can increase your risk of developing bone disease. Your drinking water does not contain more than 4 mg/l of fluoride, but does exceed EPA's secondary standard of 2.0 mg/l. We are required to notify you when we discover that the fluoride levels in your drinking water exceed 2.0 mg/l because of a cosmetic dental problem that might affect children under nine years of age.

Fluoride occurs naturally in some areas and is found in high concentrations in the aquifer in our source water. At low levels, fluoride can help prevent cavities, but children drinking water containing more than 2.0 mg/l of fluoride may develop cosmetic discoloration of their permanent teeth (dental fluorosis).

Dental fluorosis in its moderate or severe forms, may result in a brown staining and pitting of the permanent teeth. This problem occurs only in developing teeth, before they erupt from the gums. Children under nine should be provided with alternative sources of drinking water or water that has been treated to remove the fluoride to avoid the possibility of staining and pitting of their permanent teeth. You may also want to contact your dentist about proper use by young children of fluoride-containing products. Older children and adults may safely drink the water without risk of dental fluorosis.

Some home water treatment units are also available to remove fluoride from drinking water. To learn more about available home water treatment units, contact the National Sanitation Foundation (NSF) International at 1-877-8-NSF-HELP.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly. You can do this by posting this notice in a public place or distributing copies by hand or mail.

LEAD:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

NITRATE:

Even though the District meets the EPA nitrate drinking water standard, also known as a Maximum Contaminant Level (MCL), if you are caring for an infant and using tap water to prepare formula, you may want to use alternate sources of water or ask for advice from your health care provider. Nitrate levels above 10 ppm pose a particularly high health concern for infants under 6 months of age and can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness. Symptoms of serious illness include shortness of breath and blueness of the skin, known as "blue baby syndrome." Nitrate levels in drinking water can increase for short periods of time due to high levels of rainfall or agricultural activity, therefore we test for nitrate annually. The highest level for nitrate found during 2025 was 1.6 ppm, which is less than the EPA's MCL of 10 ppm.♦

DEFINITIONS:

Action Level (AL):

The concentration of a contaminant which, if exceeded, triggers treatment, or other requirements, which a water system must follow.

Maximum Contaminant Level (MCL):

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG):

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow a margin of safety.

Maximum Residual Disinfectant Level (MRDL):

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Minimum Reporting Limit (MRL):

The smallest measured concentration of a substance that can be reliably measured by a given analytical method.

Picocuries per liter (pCi/L):

Measure of the radioactivity in water.

ppm:

Parts per million or Milligrams per liter (mg/L).

ppb:

Parts per billion or Micrograms per liter (µg/L).

ppt:

Parts per trillion or Nanograms per liter (ng/L).

WATER.. USE IT WISELY!

The District strongly encourages you to use our precious water resource efficiently. Listed below are some water-wise ideas.

- Receive \$200 (and save water and money) for installing a gray water or rainwater harvesting system.
- Receive \$50 for replacing high water use toilets with a High Efficiency toilet that does not exceed 1.3 gallons of water per flush.
- Sign up for the FREE VXSmart Customer Portal at metrowateraz.watersmart.com to access detailed information about your water use.
- Check regularly for leaks, both inside and outside. A little leak can drain your wallet.
- Change your watering schedule on your drip irrigation and sprinkler systems according to the season.
- Maintain your drip irrigation and sprinkler systems.
- Water with infrequent, deep soaks. ♣

EPA WARNS NATIONALLY THAT...

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the EPA's Safe Drinking Water Hotline at 1-800-426-4791. ♣

HELP PROTECT OUR GROUNDWATER

The District and the Arizona Department of Environmental Quality (ADEQ) collect water samples each year to ensure we all have safe drinking water.

For more information on the source water assessment, call Wally Wilson, Water Resources Manager, at (520) 575-8100 or visit ADEQ's source water assessment and protection unit at <https://www.azdeq.gov/source-water-protection>. ♣

LEAD & COPPER RULE COMPLIANCE

To address lead in drinking water, public water systems were required by the EPA to develop and maintain an inventory of service line materials by October 16, 2024. Developing an inventory and identifying the location of lead service lines (LSL) is the first step for beginning LSL replacement and protecting public health. Metro Water District has not found any lead service lines at this time. For continually updated information about the inventory and lead sampling that has been done, please visit <https://metrowater.com/water-resources-quality/lead-and-copper-rule-compliance>. If you are concerned about lead in your water, contact the District at (520) 575-8100. Additional information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>. ♣



MISSION: TO DELIVER SAFE, RELIABLE WATER TO OUR CUSTOMERS.